

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

Fax No. 011 23412593, Ph. 011 23412225

No. F.6/DES/MS/School/2018/SZ/1117

Dated 20/4/18

FIRE SAFETY CERTIFICATE

Certified that Tagore International School located at E Block, East of Kailash, New Delhi-110065 comprised of Basement, Ground and three upper floors was issued FSC by this department vide letter No. F.6/MS/DFS/School/2014/SZ/1328 Dated 22/10/2014. The school premises was re-inspected by officer concerned of this department on 06/04/2018 in the presence of Sh. R.P. Singh (Asst. Admin Officer) and found that the school premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. 262/362 dated 17.01.2005 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational" Group B, as above with effect from the date of issue of this certificate for a period of **Three years** subject to compliance of the conditions mentioned below.

Issued on 20/4/18 at New Delhi by

Vipin Kental
(Vipin Kental)
Chief Fire Officer

Copy to:-

1. Principal, Tagore International School, E-Block, East of Kailash, New Delhi-110065
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhi.govt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL, 2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL, 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'F' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Vipin Kental

Tagore International School
E-Block, East of Kailash
New Delhi-110065